PSS Design Based on Fuzzy Controller with Particle Swarm Optimization Tuning

by Ermanu Azizul Hakim

Submission date: 05-Aug-2020 12:02PM (UTC+0700)

Submission ID: 1366107623

File name: PID5587617.pdf (247.21K)

Word count: 2090

Character count: 10543

PSS Design Based on Fuzzy Controller with Particle Swarm Optimization Tuning

Ermanu A. Hakim
Electrical Engineering Department
Universitas Muhammadiyah Malang
Malang, Indonesia
ermanu@umm.ac.id

Nur Kasan
Electrical Engineering Department
Universitas Muhammadiyah Malang
Malang, Indonesia
kasan@umm.ac.id

Nurhadi
Electrical Engineering Department
Universitas Muhammadiyah Malang
Malang, Indonesia
nurhadi@umm.ac.id

Abstract—The research was conducted for implementing of PSS (Power system stabilizer) which was designed based on the fuzzy logic controller (FLPSS). This approach has a main purpose for stabilizing and improving the damping of synchronous machine. The speed and active power deviation were used as fuzzy controller's inputs. The controller's output was forwarded into AVR subsequently. In order to achieve optimal setting, the optimal criteria of the Integral of Time were multiplied by the Absolute Error (ITAE). The performance of the proposed PSS under small disturbances, system parameters and loading conditions was tested. The experiment's results showed the usefulness of the specified method for damping out the system oscillations.

Key words – Fuzzy Logic Controller, Particle Swarm Optimization, power system stabilizer, synchronous machine, optimal stability,

I. INTRODUCTION

Low frequency oscillation is a common problem in power system operations. PSS (power system stabilizer) is one alternative solution to this problem. PSS can provide additional control signals for the excitation system or speed control system of the power generation unit. It can also reduce oscillations and improve dynamic performance. PSS has been extensively studied and used in power systems for many years.

Most PSS implementation comprehends the classical linear control paradigm. The PSS method is based on a linear model in a power system's default configuration. This results in a fixed parameter of PSS. This is called conventional PSS (CPSS) and is prominently used in power systems to reduce small oscillations. [1-3].

In conventional fixed-parameter spectrum controllers, gain and other parameters may not correspond to the entire spectrum of operations. Along with the growth of technological innovation, it become feasible for developing and establishing improved controllers based on a variety of sophisticated modern techniques. Power system stabilizers based on fuzzy logic, adaptive controls and artificial neural networks are being developed. Each of these control techniques has unique features and strengths. Fuzzy logic-based PSS (FLPSS) showed a significant possibility in term of increasing generator oscillation damping [6].

In this paper, fuzzy based PSS was implemented using the speed deviation and active power deviation as an inputs.

II. POWER SYSTEM MODEL

The proposed approach considered a single machine infinite bus (SMIB) system with synchronous generator provided with IEEE type-ST1 static excitation system. Fig. 1 [2] illustrates the model of the power system in linear manner. The nominal operating conditions and system parameters are given.

Fig. 1 A linear model of power system

System Data:

Generator:

$$M = 2H=7; X_d=1,81; X_q=1,76; X'_d = 0,3$$

$$L_{adu}=1,65; L_{aqu}=1,60; L_f=0,16$$

$$R_a=0,03; R_{fd}=0,0006; L_{fd}=0,153$$

$$A_{sat}=0,031; B_{sat}=6,93 \psi_T=0,8$$

Excitation System:

$$K_{AVR}=400; T_A=0,05; T_B=1,0; T_C=8,0; T_R=0,02$$

PSS:

$$T_W=1,4$$

Transmission Line:

$$X_e=0,65; R_e=0,0$$

Operation Condition:

$P=0.9; V_t=1.0; E_B=1.0; f=60 \text{ Hz}$

III. FUZZY LOGIC BASED PSS

PSS based on Fuzzy logic controller algorithm has been developed. The main objective of the proposed application was intended for stabilizing and improving the damping of the synchronous machine [4]. A speed $\Delta\omega$ and active power deviation ΔP_e are pointed as the controller input. The controller output is forwarded into the exciter module.

As can be seen in Fig. 2, the fuzzy-logic based PSS uses two input parameters including K_ω and K_p , whereas the output parameter, K_u . The input parameters selection process is generally subjective which demands the previous knowledge of fuzzy control variables (input and output signal).

Fig. 2. Schematic diagram of the FLPSS

Using the automatic rule generation and sampled data set generated by using the conventional power system stabilizer, a proper set of rules was obtained [4]. The rule used in all the following are shown in figure 3.

		Active power						
Speed deviation		NB	NM	NS	Z	PS	PM	PB
	NB	NB	NB	NB	NB	NM	NS	Z
	NM	NB	NB	NM	NM	NS	Z	PS
	NS	NB	NM	NS	NS	Z	PS	PM
	Z	NM	NM	NS	Z	PS	PM	PM
	PS	NM	NS	Z	PS	PS	PM	PB
	PM	NS	Z	PS	PM	PM	PB	PB
	PB	Z	PS	PM	PB	PB	PB	PB

Fig. 3. FLPSS rules

IV. PARTICLE SWARM OPTIMIZATION

In 1995, Kennedy and Eberhart became the pioneers for introducing the Particle swarm optimization (PSO) method [8]. Subsequently, the original Swarm algorithm was modified for improving the performance and adjusting to particular types of problems, the serial version has been implemented previously [9]-[11].

The following are the brief stages of optimization using the PSO algorithm [11]. Consider a swarm of p particles,

with each particle position describing the possible solution points in the space of the design problem of D. The position x_i is updated upon each of particle based on the following notation:

$$x_{k+1}^i = x_k^i + v_{k+1}^i \quad (1)$$

with a pseudo-velocity v_{k+1}^i can be calculated as follows:

$$v_{k+1}^i = \omega_k v_k^i + c_1 r_1 (p_k^i - x_k^i) + c_2 r_2 (p_k^g - x_k^i) \quad (2)$$

Here, subscript k denote a (unit) pseudo-time increment, p_k^i denotes the best position of particle i at time k (the cognitive contribution to the pseudo-velocity vector v_{k+1}^i), while p_k^g symbolizes the best global position in the swarm at time k (social contribution). r_1 and r_2 denotes uniform random numbers between 0 and 1. The cognitive and social scaling parameters c_1 and c_2 are systematically selected such that $c_1 = c_2 = 2$ for allowing the product $c_1 r_1$ or $c_2 r_2$ to have a mean of 1.

The particles overshoot the target half the time is the result of using these proposed values which maintains the separation within the group and if there is no overshoot occurred, it will allow for a greater area to be searched.

Fourie and Groenwold generated a comprehensive modification in the original PSO algorithm which permits the transition for searching another result as optimization progresses. This operator decreases the maximum allowed velocity v_{max} . k and the particle inertia w_k in a dynamic manner, as directed by the dynamic reduction parameters k , d , ω . For the sake of brevity, further details of this operator are neglected.

The serial PSO algorithm was performed on a single CPU computer. The total number of particles in the swarm is symbolized by the variable of p . The significant fitness value from a particular particle at design co-ordinates p_k^i is presented by f_{best}^i and the best fitness value in the overall swarm at co-ordinates p_k^g by f_{best}^g . At $k = 0$, the particle velocities v_0^i . v_0^{maks} has its initial value resided within the limits of $0 \leq v_0 \leq v_0^{maks}$. The vector v_0^{maks} is extracted from the fraction of the distance between the upper and lower bounds $v_0^{maks} = \zeta (x_{UB} - x_{LB})$ with $\zeta = 0.5$. The details of PSO algorithm is expounded as follows.

1. Initialize

- Set values constants k_{maks} , c_1 , c_2 , k , v_0^{maks} , w_k , d , and ω
- Initialize the maximum dynamic velocity v_{max} , k and inertia w_k
- Set counters $k = 0$, $t = 0$, $i = 1$. Set random number seed
- initialize randomly particle positions $x_{i0} \in D$ in R_n for $i = 1, \dots, p$
- initialize randomly particle velocities $0 \leq v_0 \leq v_0^{maks}$ for $i = 1, \dots, p$
- Evaluate fitness values f_0^i using design space co-ordinates x_{i0} for $i = 1, \dots, p$

- (g) Set $f_{best}^i = f_0^i$, $\mathbf{p}^i = \mathbf{x}_0^i$ for $i = 1, \dots, p$
- (h) Set f_{best}^g to f_{best}^i and $\mathbf{g}_0$ to corresponding $\mathbf{x}_0^i$
2. Optimize
 - (a) Update the particle of velocity vector $\mathbf{v}_{k+1}^i$ using Equation (2)
 - (b) Update the particle of position vector $\mathbf{x}_{k+1}^i$ using Equation (1)
 - (c) Update the maximum dynamic velocity $\mathbf{v}_k^{maks}$ and inertia w_k
 - (d) Evaluate the fitness value f_k^i using design space co-ordinates $\mathbf{x}_k^i$
 - (e) if $f_k^i \leq f_{best}^i$, then $f_{best}^i = f_k^i$, $\mathbf{p}^i = \mathbf{x}_k^i$
 - (f) if $f_k^i \leq f_{best}^g$ then $f_{best}^g = f_k^i$, $\mathbf{p}^g = \mathbf{x}_k^i$
 - (g) if f_{best}^g best was improved in (e) then reset $t = 0$. Else increment t
 - (h) if $t > k_{maks}$ go to 3
 - (i) if $t=d$ then multiply w_{k+1} by $(1-w_d)$ and $\mathbf{v}_{k+1}^{maks}$ by $(1-v_d)$
 - (j) if stopping condition is fulfilled, then moves to 3
 - (k) Increment i , if $i > p$ then increment k , and set $i = 1$
 - (l) Go to 2(a)
3. Report results
4. Terminate

Fig. 4. Serial PSO implementation¹¹

IV. SIMULATION RESULT

In order to analyze the capability of the PSS method for improving the power system's stability, under small perturbation and large perturbation, the dynamic performance of it was analyzed. The performance of the fuzzy logic-based PSS was thoroughly analyzed for comprehending its capacity with the CPSS method using optimized parameters generated from the phase of compensation technique.

During the nominal operating condition, A small perturbation of step increase in mechanical torque was established. The dynamic responses of the proposed PSS were comparatively analyzed with the CPSS. The proposed PSS generated lower peak over-shoots and damped out low frequency oscillations vastly compared to the CPSS approach which depicted in Fig. 5 and 6. The proposed PSS has a better damped response in overall.

FLPSS tuned PSO with the review of the optimal parameters:

$$Kp = 1.4120 \quad Kw = 0.9592 \quad Ku = 7.5346$$

show results very fast reduction as shown in the figure 5.

When compared between FLPSS and CPSS will have the ability to reduce low frequency oscillations more quickly. It as shown in Figure 6.

Fig. 5. Response to input torque $\Delta T_m = 1$ pu

Fig. 6. Response to input torque $\Delta T_m = 1$ pu $\Delta T_m = 1$ pu with Conventional PSS and FLPSS-PSO

The simulation results have shown that the fuzzy logic

controller PSS tuned proposed PSO can be an alternative to dealing with electric power system oscillations. This is shown on the attenuation performed by the controller compared to a system without PSS and PSS with conventional tuned. Selection K and KP through PSO to 30 operations at PSS Fuzzy controller based on input power and speed deviation will produce varying oscillation damping.

VII. CONCLUSION

The proposed design of optimal PSS controller based on fuzzy showed an effective results and optimal damping so that PSS could become be a stabilizer to handle damping oscillations in electrical power systems. PSS is using Fuzzy controller parameters K_p , K_ω and K_u performed using PSO with the fitness function in the form of index performance. Indeed, through this election actually can produce oscillation damping speed deviation highly effective and optimal. The simulation results of the electric power system of single-rail engine has demonstrated the ability infinite optimal stabilizer for damping low frequency oscillations and become an alternative stabilizer.

REFERENCES

- [1]. Prabha Kundur. (1994). "Power System Stability and Control". McGraw-Hill, New York, Ch.12. pp.817-822.
- [2]. Padiyar, (2008), "Power System Dynamics Stability and Control", BISA Publications, Hyderabad, Ch.8. pp 257-294.
- [3]. Larsen and D. A. Swann. (1981). "Applying Power System Stabilizers". Part I- III, *IEEE Trans. PAS* Vol. 100. no 6. pp 3017-3046.
- [4]. Ruhua You, Hassan J.E, and M. Hasyem N (2002). "An Online Adaptive Neuro-Fuzzy Power System Stabilizer for Multimachine System", *IEEE Transaction On Power System* Vol-18, Febuary,
- [5]. El-Hawary. M. (1998), *Electric Power Applications of Fuzzy Systems*, IEEE Press, New York.
- [6]. Tang K. S., Kim Fung Man, Guanrong Chen, and Sam Kwong, 2001, "An Optimal Fuzzy PID Controller", *IEEE Transactions On Industrial Electronics*, Vol. 48, No. 4, August 2001.
- [7]. J. Kennedy, R. Eberhart. (1995). "Particle swarm optimization," *Proc. IEEE Intl. Conf. Neural Networks*. 4, Nov/Dec . pp 1942 –1948.
- [8]. Ali T. Al-Awami etc, (2005). "Simultaneous Stabilization Of Power Systems Equipped With Unified Power Flow Controller Using Particle Swarm", *15th PSCC*, Liege, 22-26 August 2005
- [9]. Jun-Yi Cao and Bing-Gang Cao. (2006) "Design of Fractional Order Controller Based on Particle Swarm Optimization", *International Journal of Control, Automation, and Systems*. vol. 4, no. 6, pp. 775-781, December.
- [10]. Jaco F. Schuttler. (2005). "Evaluation of a Particle Swarm Algorithm For Biomechanical Optimization", *Journal of Biomechanical Engineering* June, Vol. 127 /465.

PSS Design Based on Fuzzy Controller with Particle Swarm Optimization Tuning

ORIGINALITY REPORT

18%

SIMILARITY INDEX

21%

INTERNET SOURCES

17%

PUBLICATIONS

14%

STUDENT PAPERS

PRIMARY SOURCES

1

www.stanford.edu

Internet Source

5%

2

www.coursehero.com

Internet Source

5%

3

www.daaam.info

Internet Source

3%

4

Submitted to ABV-Indian Institute of Information Technology and Management Gwalior

Student Paper

3%

5

www.wseas.us

Internet Source

2%

Exclude quotes On

Exclude bibliography On

Exclude matches < 2%